

# Compliance History Report 2019

## Brush Creek Water Pollution Control Facility

Parameter											
	CBOD	Suspended solids	Ammonia Nitrogen	Dissolved Oxygen	Phosphorus	Chlorine Residual	p H**	Flow	Fecal Coliform	Total Nitrogen	*****
Limit mg/L	10/20*	30	2/5*	5 min	2.0	0.18	standard units	MG/D	200/100*	M&R	
January	7	18	0.125	7.89	1.43	0	6.6	4.168	34	15	
February											
March											
April											
May											
June											
July											
August											
September											
October											
November											
December											
Yearly Avg.	7.0	18.0	0.1	7.9	1.4	0.000	6.6	4.2	34.0	15.0	

\* different limits during the summer and winter months

\*\* Between 6.0 and 9.0 standard units

M&R - Monitor and Report only - added parameter with new NPDES permit renewal

\*\*\*\*\* Total Nitrogen added to new permit