

NPDES Compliance History Report 2021

Brush Creek Water Pollution Control Facility

Limit mg/L	Parameter										*****
	CBOD	Suspended solids	Ammonia Nitrogen	Dissolved Oxygen	Phosphorus	Chlorine Residual	p H** standard units		Flow MG/D	Fecal Coliform	Total Nitrogen
	10/20*	30	2/5*	5 min	2.0	0.18	6.0	9.0	8.73	200/100* 2100/100*	M&R
January	< 2.0	<2.0	0.04	7.6	1.06	0	6.5	7.0	3.764	<1.0	30
February											
March											
April											
May											
June											
July											
August											
September											
October											
November											
December											
Yearly Avg.	0.0	0.0	0.0	7.6	1.1	0.000	6.5	7.0	3.8	0.0	30.0

* different limits during the summer and winter months

** Between 6.0 and 9.0 standard units

M&R - Monitor and Report only - added parameter with new NPDES permit renewal

***** Total Nitrogen added to new permit

NOTE: ALL DATA (INCLUDING FLOW) VALUES ARE MONTHLY AVERAGES AS REQUIRED BY PERMIT