

# NPDES Compliance History Report 2022

## Brush Creek Water Pollution Control Facility

Limit mg/L	Parameter											
	CBOD 10/20*	Suspended solids 30	Ammonia Nitrogen 2/5*	Dissolved Oxygen 5 min	Phosphorus 2.0	Chlorine Residual 0.18	p H** standard units 6.0	9.0	Flow MG/D 8.73	Fecal Coliform 200/100* 2100/100*	Total Nitrogen M&R	*****
January	< 2.0	<2.0	0.49	6.84	1.12	0	6.9	7.3	3.747	<1.0	14.5	
February												
March												
April												
May												
June												
July												
August												
September												
October												
November												
December												
Yearly Avg.	0.0	0.0	0.5	6.8	1.1	0.000	6.9	7.3	3.7	0.0	14.5	

\* different limits during the summer and winter months

\*\* Between 6.0 and 9.0 standard units

M&R - Monitor and Report only - added parameter with new NPDES permit renewal

\*\*\*\*\* Total Nitrogen added to new permit

**NOTE: ALL DATA (INCLUDING FLOW) VALUES ARE MONTHLY AVERAGES AS REQUIRED BY PEI**

